

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE

NEW DELHI- 110001

No.F6/DFS/MS/School/2022/SZ/1312

Dated: 14/12/22

FIRE SAFETY CERTIFICATE

Certified that the R.P. Memorial Public School, K-3, Mohan Garden, Uttam Nagar, New Delhi-110059, comprised of ground plus three upper floors & four rooms at terrace floor which is use for residence purpose, owned/occupied by R.P. Memorial Public School was issued FSC vide letter No. F.6/DFS/MS/09/1617 dated 03.06.09 (For GF & FF only). The school building was inspected by the officer concerned of this department on 21/11/2022 in the presence of Sh. Ravinder Yadav (Manager) and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class "Educational" w.e.f. the date of issue of this certificate for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on.....14/12/22..... at New Delhi by



(Atul Garg)

Director

Delhi Fire Service

Copy to:-


1. The Principal, R.P. Memorial Public School, K-3, Mohan Garden, Uttam Nagar, New Delhi-110059.
2. Director of Education, GNCT of NCT of Delhi, Old Secretariat.

Following fire safety directives must be adhered to:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in



R.P. Memorial Public School
K-3, Mohan Garden
Uttam Nagar, New Delhi 110059



HOS/Vice Principal
R.P. MEMORIAL PUBLIC SCHOOL
(Recognised)
K-3, Mohan Garden
Uttam Nagar New Delhi-110059